


Stopping Plugs, Metal, Hexagon Socket Head

SP.MA.NPT1/2.BN.X.20.K50

- Stopping plug for unused cable entries
- Brass nickel-plated
- Thread NPT 1/2"
- Without head, installation by means of allen key
- Ex db, Ex eb and Ex tb certified
- Suitable for operation in Zone 1, Zone 2, Zone 21 and Zone 22
- Suitable for operation in Class I, Zone 1/2/22
- Suitable for operation in Class I, Division 2 when installed in accordance with NEC501.10(B)(2)
- Degree of protection IP66 / IP68, UL Type 4X
- Packaging unit: 50 pieces, without accessories



Dimensions



Details see data table

| Legend | |
|--------|---------------|
| 1 | Stopping plug |
| KS | Key size |
| L | Total length |
| TD | Thread size |
| TL | Thread length |

Technical Data

Mechanical specifications

| | |
|----------------------|--------------------------|
| Thread type | NPT ANSI ASME B1.20.1 |
| Thread size (TD) | NPT 1/2" |
| Degree of protection | IP66 / IP68 , UL Type 4X |
| Material | |

Technical Data

| | |
|--|--|
| Finish | inherent color silver |
| Stopping plug | brass, nickel-plated |
| Mass | |
| Individual component | approx. 42 g |
| Packing unit | approx. 2.31 kg |
| Dimensions | |
| Thread length (TL) | 20 mm |
| Total length (L) | 20 mm |
| Key size (KS) | 10 mm |
| Tightening torque | |
| Nut torque at enclosure (SW1) | 8 Nm |
| Ambient conditions | |
| Ambient temperature | -60 ... 130 °C (-76 ... 266 °F) |
| Data for application in connection with hazardous areas | |
| EU-type examination certificate | CESI 15 ATEX 029X |
| Marking | Ⓜ II 2 GD Ex db IIC Gb Ex eb IIC Gb Ex tb IIIC Db |
| International approvals | |
| UL approval | |
| cULus | E305142 tested to UL 50E and UL 508A CSA C22.2, No. 14-13 |
| IECEx approval | IECEx CES 15.0006X |
| UKCA approval | CML 22 UKEX 1267X |
| CCC approval | 2021312313000343 |
| Conformity | |
| Degree of protection | EN 60529 |
| General information | |
| Delivery quantity | 50 |
| Scope of delivery | Stopping Plugs, Metal, Hexagon Socket Head Brief instructions (1 copy) |
| Supplementary information | EC-Type Examination Certificate, Statement of Conformity, Declaration of Conformity, Attestation of Conformity and instructions have to be observed where applicable. For information see www.pepperl-fuchs.com . |